

**Building Code
Commission**

2nd Floor, 777 Bay Street
Toronto, ON M5G 2E6
Telephone: 416 585-6508
Facsimile: 416 585-7521
<http://bbc.mah.gov.on.ca/>

**Commission
du code du bâtiment**

777, rue Bay, 2^e étage
Toronto, ON M5G 2E6
Téléphone: 416 585-6508
Télécopieur: 416 585-7521
<http://bbc.mah.gov.on.ca/>



February 7, 2005

PARTIAL RULING FAX

To: JANE DON WARREN
ECO-BLOCK

PAGES: 1 + 2

Fax: (905) 469-0165

TO: Walter Harhay - (416) 620-7392
Harold Locke - (604) 733-8411
Jim Laughlin - (416) 392-0877
Peter Au - (416) 392-0721

FROM: Sally England-Bizjak, Secretary
Building Code Commission (BCC)

RE: BCC APPLICATION # 2004-47

Please find attached Partial Decision # 04-51-1008 for the above file. The full Decision will be made available once it has been finalized, however, the attached portions, as provided to you now, will not be altered.

Please feel free to let me know if you need any additional information for your files.

Sincerely,

for Sally England-Bizjak


Partial Ruling 04-51-1006 (File 2004-50)**7. Commission Ruling**

It is the decision of the Building Code Commission that the proposed exterior wall system that incorporates foam plastic insulation and exterior cladding provides sufficiency of compliance with Sentences 3.2.3.7.(1) and 3.1.5.11.(3) of the Building Code, at 42-44 Camden Street, Toronto, Ontario.

8. Reasons

- i) The exterior cladding has been tested to CAN4-S114 "Standard Method of Test for Determination of Non-combustibility in Building Materials" and meets the material requirements for noncombustibility as defined in the Code.
- ii) The ECO-Block wall forming system has been tested to CAN/ULC S101-M "Standard Methods of Fire Endurance Tests of Building Construction and Materials".
- iii) The ECO-Block wall, including insulation, terminates at the underside of each floor slab creating a fire-break and fire compartments at each floor level.
- iv) CCMC Evaluation Report No. CCMC 12986-R and Minister's Ruling No. 04-12-116 have (12986-R) approved this wall forming system for limited use. In this particular application, sealed architectural drawings and certification by a Professional Engineer under Part 4 of the Code have been submitted.
- v) There are no unprotected openings penetrating this exterior wall assembly.


Dated at Toronto this 17th day in the month of January in the year 2005 for application number 2004-50.



Tony Chow, Chair



Susan Friedrich



Rick Florio